



# Certificate of Compliance

**Certificate:** 1352450

**Master Contract:** 240515

**Project:** 2685306

**Date Issued:** December 10, 2013

**Issued to:** Telemecanique/Schneider Electric

Industries SAS  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
France  
Attention: Christophe Delaitre

*The products listed below are eligible to bear the CSA Mark shown*



*Anne Drouin*

**Issued by:** Anne Drouin

## **PRODUCTS**

**CLASS 3211 03** - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Photo-electric sensors Cat. No. XUM, followed by 0, 1, 2, 5, 6 or 9, followed by A, followed by K, N or P, followed by A, B or S, followed by A or N, followed by L2 or M8, may be followed by R or T. Types 4X indoor, 12 and 13 enclosures. Rated 24V dc, 0.1A resistive.

## **APPLICABLE REQUIREMENTS**

CSA-C22.2 No. 14-13 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures