



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2004010305110000

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

SCHNEIDER ELECTRIC INDUSTRIES SA (V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

PRODUCT NAME, MODEL AND SPECIFICATION

Inductive Proximity Switch

XSA-V: Ui:240V; AC-140, DC-12; Ue: 12-48V DC, 24-240V AC/DC; Ie: 200mA DC, 5-350mA AC/5-200mA DC; Sn=10mm; f=6-150 impulses/minute, 120-3000 impulses/minute; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2016

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462142-2019.

Valid from: Aug.25,2020

Valid until: Aug.17,2025

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>



产品认证证书

证书编号: CQC2004010305110000

申请人名称及地址

施耐德电气(中国)有限公司上海分公司
上海市普陀区绥德路669号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

SCHNEIDER ELECTRIC INDUSTRIES SA (V054246)
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

产品名称和系列、规格、型号

电感式接近开关

XSA-V: Ui:240V; AC-140, DC-12; Ue: 12-48V DC, 24-240V AC/DC; Ie: 200mA DC, 5-350mA
AC/5-200mA DC; Sn=10mm; f=6-150 impulses/minute, 120-3000 impulses/minute; IP67; 型号解
释见附件

产品标准和技术要求

GB/T 14048.10-2016

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求, 特发此证。

发证日期: 2020 年 08 月 25 日 有效期至: 2025 年 08 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任:

陆楠



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2004010305110000

纸号: 372759

型号解释:

XSA-V	1	2	801	L05
I	II	III	IV	V

I	开关类型 XSA-V-用于旋转监控的电感式接近开关
II	通电延时, 0- 没有延时 1-9 s 3-3 s
III	直径和操作频率 1-30mm 和 6...150 脉冲/分 2-30mm 和 120...3000 脉冲/分
IV	输出模式 373-3 线 DC, 带过载和短路保护 801-2 线 AC/DC
V	可选 字母或数字, 代表线缆长度或运行温度扩展 如: 空白 - 2m 电缆 L05 - 5m 电缆 TT- 运行温度扩展到-25 到 +85°C TF- 运行温度扩展到-40 到 +70°C

注: 此附录与证书同时使用时有效。

主任: 陆梅



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>