



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2004010305110000

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

SCHNEIDER ELECTRIC INDUSTRIES SA
52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

PRODUCT NAME, MODEL AND SPECIFICATION

Inductive Proximity Switch

XSA-V: Ui:240V; AC-140, DC-12; Ue: 12-48V DC, 24-240V AC/DC; Ie: 200mA DC,
5-350mA AC/5-200mA DC; Sn=10mm; f=6-150 impulses/minute, 120-3000 impulses/minut
e; IP67

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.10-2016

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification (REFNO.CNCA-C03-02:2014).

Valid from: Aug.17,2020**Valid until:**Aug.17,2025

The validity of the certificate is subject to positive result of the regular follow up
inspection by issuing certification body until the expiry date.

Date of original issued: Mar.08,2004

The certificate information is available through CNCA's website: www.cnca.gov.cn

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

证书编号: 2004010305110000

委托人名称、地址

施耐德电气(中国)有限公司上海分公司

上海市普陀区绥德路 669 号

生产者(制造商)名称、地址

Schneider Electric Industries SAS

35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称、地址

SCHNEIDER ELECTRIC INDUSTRIES SA

52 Rue De Dion Bouton ZI Nord F-87280 LIMOGES France

产品名称和系列、规格、型号

电感式接近开关

XSA-V: Ui:240V; AC-140, DC-12; Ue: 12-48V DC, 24-240V AC/DC; Ie: 200mA DC, 5-350mA AC/5-200mA DC; Sn=10mm; f=6-150 impulses/minute, 120-3000 impulses/minute; IP67;

型号解释见附件

产品标准和技术要求

GB/T 14048.10-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2020 年 08 月 17 日有效期至: 2025 年 08 月 17 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2004 年 03 月 08 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询

经中国合格评定国家认可委员会认可 CNAS C001-P



主任:

陆楠



中国质量认证中心



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2004010305110000

纸 号: 2626144

型号解释:

XSA-V	1	2	801	L05
I	II	III	IV	V

I	开关类型 XSA-V-用于旋转监控的电感式接近开关
II	通电延时. 0- 没有延时 1- 9 s 3- 3 s
III	直径和操作频率 1- 30mm 和 6...150 脉冲/分 2- 30mm 和 120...3000 脉冲/分
IV	输出模式 373- 3 线 DC, 带过载和短路保护 801- 2 线 AC/DC
V	可选 字母或数字, 代表线缆长度或运行温度扩展 如: 空白 - 2m 电缆 L05 - 5m 电缆 TT- 运行温度扩展到-25 到 +85°C TF- 运行温度扩展到-40 到 +70°C

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心