



Certificate of Compliance

Certificate: 1352450

Master Contract: 240515

Project: 2685306

Date Issued: December 10, 2013

Issued to: Telemecanique/Schneider Electric

Industries SAS
Zone Industrielle No. 3
L'Isle d'Espagnac, 16340
France
Attention: Christophe Delaitre

The products listed below are eligible to bear the CSA Mark shown



Anne Drouin

Issued by: Anne Drouin

PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

Photo-electric sensors Cat. No. XUM, followed by 0, 1, 2, 5, 6 or 9, followed by A, followed by K, N or P, followed by A, B or S, followed by A or N, followed by L2 or M8, may be followed by R or T. Types 4X indoor, 12 and 13 enclosures. Rated 24V dc, 0.1A resistive.

APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-13 - Industrial Control Equipment

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures