

# Certificate of Compliance

**Certificate:** 1012487 (LR 44087-109)

**Master Contract:** 164581

**Project:** 1156126


**Date Issued:** December 13, 2000

**Issued to:** **TELEMECANIQUE/SCHNEIDER ELECTRIC  
INDUSTRIES S.A.**  
33 Bis, Avenue du Marechal Joffre  
B.P. 204  
92002 Nanterre Cedex  
France

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** M. Legault, Eng.

**Signature:** 

## PRODUCTS

CLASS 3211 03 - INDUSTRIAL CONTROL EQUIPMENT - Motor Controllers - Auxiliary Devices

PART A - Photo-Electric Detectors, Cat. No. XU, followed by 1, 2, 5, 8 or 9, followed by M, N, P, or S, followed by 18, followed by A, K, M, N, P or U1, may be followed by A, B, C or P, may be followed by a two or three digit number, may be followed by D, K, R, T, W or L with one or two digit number, or an association of these digits, cylindrical polymeric or metallic, Type 4X indoor and Type 12, cord connected or connector. Models XU.-N, -P and -S are rated: 12-24V dc, 100mA, while Model XU.-M is rated 12-24V dc, 100mA or 24-240V ac/dc, 200mA resistive load.

## APPLICABLE REQUIREMENTS

CSA-C22.2 No. 14-95	-	Industrial Control Equipment
CAN/CSA-C22.2 No. 94-M91	-	Special Purpose Enclosures